

FORT WAINWRIGHT FIRE & EMERGENCY SERVICES

Fire Extinguishers

Assistant Chief of Fire Prevention
 John E. Serrato 907-353-9164
 john.e.serrato.civ@mail.mil
 Fire Prevention Office 1049 Chena
 Road Apt. 9 Fort Wainwright AK.,
 99703

In accordance with (IAW)UFC 3-600-01 8 August 2016 Change 2, 25 March 2018 9-17 PORTABLE FIRE EXTINGUISHERS. 9-17.1 General purpose portable fire extinguishers are not required when the Facility is provided with complete automatic sprinkler protection and a fire alarm system IAW this UFC. 9-17.2 When provided, portable fire extinguishers must be located IAW NFPA 10

IAW with AR-420-1,25-33. All fire extinguishers will be Underwriter's Laboratories (UL) listed or Factory Mutual (FM) approved. a. Facilities. The facilities engineer or user will furnish the initial purchase and installation of fire extinguishers in newly constructed facilities and their replacement in existing facilities, per NFPA 101, Life Safety Code. The fire department will inspect and determine the type, size, and location of extinguishers per NFPA 10, Portable Fire Extinguishers. Garrisons will not furnish portable fire extinguishers in Family housing areas, unless required by NFPA101.

DISPOSAL/REMOVAL:

Contact your Unit Safety Representative and/or DPW for turn-in locations for serviceable extinguishers that are suitable for redistribution to facilities still requiring fire extinguishers.

Occupancy	Sprinkler System Installed	General Purpose Extinguishers Required	Hazardous Areas That Require Extinguishers <i>*Contact the FWFES Fire Prevention Office for further guidance*</i>
Assembly	No	✗	- Kitchens - Flammable Storage - Food warming areas
	Yes	✗	
Health Care	Yes or No	✓	- All areas
Dormitory/Barracks Lodging	No	✗	- Arms Rooms - Maintenance Areas - Flammable Storage - Laundries > 100 ft ² - Trash Collection Rooms
	Yes	✗	- Arms Rooms - Flammable Storage
Business	No	✓	- Training systems (cockpit/vehicle) - Wheeled egress trainers - Areas not evacuated - Flammable storage - Arms Rooms
	Yes	✗	
Industrial	No	✗	- Flammable storage areas - Laboratories - Boiler rooms - DPW shop area - Welding areas - Motor pools - Paint spraying/booths - Soldering areas - Repair garages - Battery room - Dip tanks - Multimedia laboratories - Laundries/Dry Cleaners - Explosives handling - Arms Rooms
	Yes	✗	
Storage	No	✗	- Flammable storage - Arms Rooms - Explosives Handling - Material Handling Equipment w/internal combustion engine
	Yes	✗	

This document was established as a quick reference guide and is not all inclusive. Please contact the Fire Prevention Office for assistance in determining your fire extinguisher requirements.