

FIRE EXTINGUISHERS (BUILDING)

AREAS OF CONCERN

Building fire extinguishers pose a risk to health and safety when discharging. DPW Supply provides initial fire extinguishers to replace the old CO2 (carbon dioxide) or water (silver bullet) fire extinguishers.

CHARACTERIZATION

Building fire extinguishers may contain residue that could be an irritant.

HANDLING PROCEDURES

INITIAL REPLACEMENT OF BUILDING FIRE EXTINGUISHERS (missing from building or building only contains CO2 and/or water extinguishers)

Go to **DPW Supply, Bldg. 5122, 3rd St & Wickham Ave** with service order number to obtain Fire Extinguishers.

DISCHARGED BUILDING FIRE EXTINGUISHER

- IAW IMCOMS new policy Portable fire extinguishers are personal property and are not Installed Building Equipment (IBE) (Real Property) - please see AR 420-1, Chapter 4-60.
- IMCOM DPW's are only responsible for the maintenance, repair, and replacement of IBE (real property), not personal property mobile/servable equipment.
- Not a QEMS nor a QDEH requirement for the Garrison to fund replacement and maintenance of these portable fire extinguishers.
- After initial issue - any follow-on maintenance, repair, and replacement of these portable fire extinguishers then becomes the Facility Manager's (tenant's) responsibility.

NOTE: Take all CO2, water, old out of date, or discharged fire extinguishers to **PPOC Fire Extinguishers** at Bldg. 5209, Desert Storm and Oregon Ave for disposal
Phone number (270)-956-1420.



GENERAL INFORMATION

NOTE: Units will be responsible for the servicing of the building Fire Extinguishers either through their supply or S4 sections

FIRE EXTINGUISHERS (VEHICLE/EQUIPMENT)

AREAS OF CONCERN

Fire extinguishers pose a risk to health and safety when discharging. The Pollution Prevention Operations Center (PPOC) has implemented a program for exchange of tactical vehicle/equipment fire extinguishers (separate from building extinguishers). Do not remove building fire extinguishers and use for equipment such as your FARP or other training missions. **Check the TM/FM for appropriate size/type Fire Extinguisher.** The PPOC can assist in determining the correct extinguisher for your application.

CHARACTERIZATION

Vehicle/equipment fire extinguishers may contain residue that could be an irritant.

HANDLING PROCEDURES

DO NOT DRILL HOLES, REMOVE HEADS, OR DISCHARGE VEHICLE/EQUIPMENT FIRE EXTINGUISHERS

- Step 1** Bring unserviceable or excess vehicle/equipment/Halon fire extinguishers to the **PPOC Fire Extinguishers** at Bldg 5209, Desert Storm and Oregon Ave for disposal between 0700 – 1100 and 1300 -1500. (**Do Not** discharge or empty).
- Step 2** If the PPOC has a serviceable fire extinguisher in stock, you may pick up one in exchange.
- Step 3** If no fire extinguishers are in stock, you may receive one within 3 – 4 weeks.

NOTE: PPOC Fire Extinguishers section does not service vehicle suppression systems (powder, Halon, HFC-227, etc). Coordinate with your Unit Supply and/or Unit Maintenance Officer first for disposition and issuance at your supporting SSA facility. Division G4 maintenance will assist if requested from the unit

NOTE: Turn-in of unserviceable AFES bottles will be done by the unit supply section and/or the maintenance section to their supporting SSA.



GENERAL INFORMATION

For additional information on types and availability of building fire extinguishers contact the **Ft. Campbell Fire Department Station 3**. For additional information on vehicle fire extinguishers, and DOT transportation requirements, contact **PPOC Support**.