

Appendix E

Prescribed Temperatures (Fahrenheit)

Table E-1. Prescribed Temperatures (Fahrenheit)

Area ¹	Heating Temp Range ²	Cooling Temp Range ²	Hot Water Temp ^{1 and 3}
Family quarters	65– 70 (18.3 – 21.1)	75 – 80 (23.9 – 26.7)	110 (43.3)
Troop living	65 – 70 (18.3 – 21.1)	75 – 80 (23.9 – 26.7)	110 (43.3)
Administrative areas	65 – 70 (18.3 – 21.1)	75 – 80 (23.9 – 26.7)	Administrative shower facilities 110 (43.3)
Dining facility	65 – 70 (18.3 – 21.1)	75 – 80 (23.9 – 26.7)	General use – 140 (60) Prewash – 160 (71.1) Final rinse – 180 (82.2)
Recreation	65 – 70 (18.3 – 21.1)	75 – 80 (23.9 – 26.7)	96 (35.6)
Motor pools	50 – 65 (10.0 – 15.6)	N/A	N/A
Dental clinics	70 – 75 (21.1 – 23.9)	70 – 75 (21.1 – 23.9)	140 (60)
Medical clinics	70 – 75 (21.1-23.9)	70 – 75 (21.1 – 23.9)	140 (60)
Child care	70 – 75 (21.1 – 23.9)	70 – 75 (21.1 – 23.9)	95 (35.6)
Operating-delivery	70 – 75 (21.1 – 23.9)	65 – 70 (18.3 – 21.1)	140 (60)
Intensive care	75 – 80 (23.9 – 26.7)	70 – 75 (21.1 – 23.9)	140 (60)
Paint shop	75 – 80 (23.9 – 26.7)	N/A	N/A
Warehouse	55 – 60 (12.8 – 15.6)	N/A	N/A
Automated facility	PMS	PMS	N/A