



Georgia Department of Natural Resources

Environmental Protection Division
Underground Storage Tank Management Program
4244 International Parkway, Suite 104, Atlanta, Georgia 30354
Lonice C. Barrett, Commissioner
Harold F. Rehms, Director
(404)362-2687

June 14, 1999

Colonel Ovidio E. Perez
Director, Public Works
U.S. Army/HQ3d Inf. Div. (Mech.)
1557 Frank Cochran Drive
Ft. Stewart, GA 31314-4928

SUBJECT: Corrective Action Plan - Part A
Hunter AAF, Former USTs #27 and #28
Building 8059
Savannah, GA; Chatham County
Facility ID: 9025083*1

Dear Colonel Perez:

This is to acknowledge your letter, dated March 24, 1999, that forwarded a properly certified Corrective Action Plan - Part A for our review.

We have conducted a technical review of the CAP-Part A. The bases for this review are the CAP-Part A content requirements referenced in paragraph 391-3-15-.09(2) of the Georgia Rules for Underground Storage Tank Management (GUST Rules, revised 1995). Our comments on deficiencies are outlined in the enclosure. Please amend the CAP-Part A to correct these by July 14, 1999. Unless one of the outlined EPD Comments requests otherwise, you are required to only submit your responses to these comments as an Addendum to the original CAP-Part A. Complete submittal of the CAP-Part A is not necessary.

If you have any questions, please contact the undersigned at (404)362-2687.

Sincerely,

William E. Logan
Geologist
Corrective Action Unit II

WEL;
s:\landdocs\william\pending99\9025083.15

cc: John B. Reeves, P.E., SAIC
Lisa L. Lewis, GA EPD
Larry Rogers, EPD Coastal District

File (CA): Chatham; 9025083

EPD Comments

**Hunter AAF, Former USTs #27 and #28
Building 8059
Savannah, GA; Chatham County**

Facility ID: 9025083*1

June 14, 1999

1. The CAP-A stated that the soil sample collected during the closure of the gasoline tank contained toluene at 13.3 mg/kg and ethylbenzene at 12.6 mg/kg which exceeded the applicable Table A Soil Threshold Levels of 6 mg/kg and 10 mg/kg. The CAP-A report did not address this soil contamination. If you do not plan to remediate the contaminated soil in the former gasoline tank pit, please calculate Alternative threshold Levels (ATLs) for the contaminated soil.