datafolders admin todays date notified Asturison & Whete

Georgia Department or Natural Resources

Environmental Protection Division

Underground Storage Tank Management Program 4244 International Parkway, Suite 104, Atlanta, Georgia 30354

Chris Clark, Commissioner F. Allen Barnes, Director (404) 362-2687

February 5, 2010

Mr. Thomas C. Fry U.S. Army/HQ 3d,Inf. Div (Mech) Directorate of Public Works 1550 Frank Cochran Drive Building 1137 Fort Stewart, Georgia 31314-4927

SUBJECT: Notice to Implement Corrective Action Plan (CAP)-Part B:

Hunter AAF, Former Fuel Pit #1

Former Building 8060

Savannah, Chatham County, GA

Facility ID: 9025085*1

Dear Mr. Thomas C. Fry:

The Georgia Underground Storage Tank Management Program (USTMP) has received your consultant's letter, dated November 5, 2009, that forwarded a properly certified Revised CAP-Part B Addendum #1.) The report was prepared by ARCADIS.

The technical proposal contained in the Revised CAP-Part B for further investigation, monitoring and/or remediation of the current release is hereby approved by the USTMP. As a result of your CAP-Part B being technically approved, you are authorized to begin implementation of this plan.

Note: EPD recommends that an additional line of injection wells be located downgradient of D-MW-34 to reduce the "Leading Edge" of the dissolved plume. Also, additional monitoring wells will be necessary to monitor site conditions downgradient of D-MW-34.

Please submit an updated milestone schedule by **March 8, 2010**, listing specific dates, events and a timetable to complete the proposed activities. If you have any technical questions, please contact me at (404) 362-4529.

William E. Logar

Geologist III

Corrective Action Unit II

WEL:

S: land/landdocs/williaml/Pend10/9025085R1A, 120

cc: Curtis Scott Bostian, P.E., ARCADIS

Lisa L. Lewis, GA EPD

File (CA): CHATHAM; 9025085