tonia 5/25/99

Georgia Department of Natural Resources

Environmental Protection Division

Underground Storage Tank Management Program
4244 International Parkway, Suite 104, Atlanta, Georgia 30354
Lonice C. Barrett, Commissioner
Harold F. Reheis, Director
(404)362-2687

May 13, 1999

Colonel Ovidio E. Perez Director, Public Works U.S. Army/HQ3d Inf. Div. (Mech.) 1557 Frank Cochran Drive Ft. Stewart, GA 31314-4928

UST 67

SUBJECT:

No Further Action Required Building 967 Area, UST #67 Wilson Avenue, West of 6th Street Ft. Stewart, GA; Liberty County Facility ID: 9089021*1

Dear Colonel Perez:

This is to acknowledge your letters, dated January 14, 1999 and March 11, 1999, that forwarded a response to comments, and a revised site ranking form, for our review.

We have conducted a technical review of the response to the comments. The basis for this review is the CAP-A content referenced in paragraph 391-3-15-,11(3) of the Georgia Rules for Underground Storage Tank Management (GUST Rules). The Georgia Environmental Protection Division (EPD) has determined that, for the current release, no further action is required for contamination related to the subject location, at this time.

However, the site could be subject to corrective action in the future if mandated through more stringent State or Federal statutory or regulatory changes, if drinking water systems are identified or installed within two miles of the site, if surface water bodies are impacted by any dissolved contamination, resulting from this release, or if previously unidentified soil contamination, dissolved contamination and/or free product on groundwater are identified as originating from this site.

If you have any questions, please contact the undersigned at (404)362-2687.

Sincerely.

Unit Coordinator

Corrective Action Unit II

WEL;

s:\landdocs\williaml\pending99\9089021.34

cc:

Patricia Stoll, P.E., SAIC William E. Logan, GA EPD Larry Rogers, EPD Coastal District

File (CA): Liberty; 9089021