

*James Welton
7/25/98*

Georgia Department of Natural Resources

Environmental Protection Division
Underground Storage Tank Management Program
4244 International Parkway, Suite 104, Atlanta, Georgia 30354
Lonice C. Barrett, Commissioner
Harold F. Reheis, Director
(404)362-2687

July 17, 1998

Mr. John H. Spears
US Army / HQ3rd Infantry Div. (Mech.)
1557 Frank Cochran
Ft. Stewart, GA 31314-4928

SUBJECT: Corrective Action Plan (CAP)-Part B:
Building 1333 Area, USTs 90 and 91
McFarland Avenue south of W. 15 Street
For Stewart, GA; Liberty County
Facility ID: 9089075*1

Dear Mr. Spears:

This is to acknowledge your letter, dated February 23, 1998, that forwarded a properly certified Corrective Action Plan (CAP)-Part B, for our review. The report was prepared by Science Applications International Corp.

The technical proposal contained in Section III of the CAP-Part B for the proposed monitoring actions for contaminated media resulting from the referenced release at the subject location, are hereby approved by EPD. As a result of your CAP-B being technically approved, you are authorized to begin implementation of this plan, with the one contingency outlined on the attached comment page.

Please submit an updated milestone schedule, listing specific dates, events, and a time table to complete the proposed activities, by August 17, 1998.

If you have any questions, please contact the undersigned at (404)362-2687.

Sincerely,



William E. Logan
Environmental Specialist
Corrective Action Unit

WEL;
g:\landdocs\william\zina\tetra3\9089075.120

Enclosure -1

cc: Patricia Stoll, P.E., Science Applications International Corp.
Lisa L. Lewis, EPD

File (CA): Liberty; 9089075

*** US7 Upgrade Deadline - December 22, 1998 ***

EPD Comments

**Corrective Action Plan (CAP)-Part B:
Building 1333 Area, USTs 90 and 91
McFarland Avenue south of W. 15 Street
For Stewart, GA; Liberty County**

Facility ID: 9089075*1

May 29, 1998

1. Current GUST guidance requires that all samples collected after April 1, 1998 must be analyzed for BTEX using the new EPA Method 8021B, rather than the previous 8020 method. Please be sure to analyze all samples using this new method.

**** UST Upgrade Deadline - December 22, 1998 ****