

RECEIVED

OCT 27 2006

PAGE..... OF.....

Scanned 2/10/07
Algeana, Randy & Dal
cc Tressa + Jan

Georgia Department of Natural Resources

Environmental Protection Division
Underground Storage Tank Management Program
4244 International Parkway, Suite 104, Atlanta, Georgia 30354
Noel Holcomb, Commissioner
Carol A. Couch, Ph.D., Director
(404) 362-2687

October 24, 2006

Ms. Algeana Stevenson
Directorate, Public Works
U.S. Army/HQ3d Inf. Div. (Mech.)
1550 Frank Cochran Drive
Ft. Stewart, GA 31314-4927

SUBJECT: Notice to Implement Corrective Action Plan (CAP)-Part B: *Progress Report*
Building 275, USTs 208 & 209 Site
Bultman Avenue, East of E 1st Street
Ft. Stewart, Liberty County, GA
Facility ID: 9089036*1

Dear Ms. Stevenson:


The Georgia Underground Storage Tank Management Program (USTMP) has received your consultant's letter, dated September 28, 2006, that forwarded a Revised CAP-Part B. The report was prepared by US Army of Corps of Engineers (USACE)-Savannah District.

The technical proposal contained in the CAP-Part B for further investigation, monitoring and/or remediation of the current release is hereby approved by the USTMP. As a result of your CAP-Part B being technically approved, you are authorized to begin implementation of this plan.

Please note: Two or more monitoring wells to be installed as needed with the diameter ranging from 2-inch to 4-inch monitoring wells pending on the amount of free-product observed. Recommend the use of a vacuum pump or truck mounted vacuum recovery system to assist in the recovery of free product.

Please submit an updated milestone schedule by **December 29, 2006**, listing specific dates, events and a timetable to complete the proposed activities. If you have any technical questions, please contact me at (404) 362-4529.

Sincerely,



William E. Logan
Senior Geologist
Corrective Action Unit II

WEL:

S: land/landdocs/williaml.pending06/9089036. 120

cc: Anna H. Butler, USACE-Savannah

Lisa L. Lewis, GA EPD

File (CA): LIBERTY; 9089036