

Georgia Department of Natural Resources

Environmental Protection Division

Underground Storage Tank Management Program

4244 International Parkway, Suite 104, Atlanta, Georgia 30354

Lonice C. Barrett, Commissioner

Harold F. Reheis, Director

(404)362-2687

July 23, 1997

Mr. John H. Spears
U.S. Army/HQ 3d Inf. Div. (Mech)
Attn: AFXP-DEV (Spears)
Building 1139
Fort Stewart, Georgia 31314-5000

SUBJECT: **Notice to Implement Corrective Action Plan (CAP):**
Building 1325 Area, USTs 95, 96 & 97 Site
Wilson Avenue North of W. 15th Street
Fort Stewart, GA; Liberty County
Facility ID: 9089077


Dear Mr. Spears:

This is to acknowledge your consultant's letter, dated March 31, 1997, that forwarded a properly certified CAP-Part A for our review.

The technical proposal, contained in Sections 1. through 4. of the CAP-Part A for proposed investigative and/or remedial actions for contaminated media resulting from the referenced release at the subject location is hereby approved by the Environmental Protection Division with the attached EPD comments. As a result of your CAP-Part A being technically approved, you are authorized to begin implementation of this plan.

Please submit an updated milestone schedule by August 23, 1997, listing specific dates, events and a timetable to complete the proposed activities. If you have any technical questions, please contact me at (404)362-2687.

Sincerely,


Kenneth F. White, Ph.D.
Environmental Specialist
Corrective Action Unit

Enclosure

cc: Lisa L. Lewis, GA EPD
Patricia Stoll; SAIC
File (CA): Liberty; 9089077

EPD Comments

**Corrective Action Plan CAP-Part A:
Building 1325 Area, USTs 95, 96 & 97 Site
Wilson Avenue North of W. 15th Street
Fort Stewart, GA; Liberty County
Facility ID: 9089077**

July 23, 1997

1. The northern most and southern most monitoring well proposed in the Site Investigation Plan are lateral (cross gradient) to the direction of the groundwater flow. Please consider moving both well locations toward the western most proposed well to a position that is generally downgradient of the UST pit and dispenser locations (approximately 45 degrees or less north and south of the groundwater flow line passing through the release site.)
2. In order to detect free product if present, please screen all wells across the water table.