

**FORT STEWART/HUNTER ARMY AIRFIELD**  
**DAILY/MONTHLY STORMWATER INSPECTION CHECKLIST**

**CHECK MARK = SATISFACTORY**  
**X = UNSATISFACTORY**

<b>CHECKED DAILY:</b>	<b>WK 1</b>	<b>WK 2</b>	<b>WK 3</b>	<b>WK 4</b>	<b>WK 5</b>	<b>ECO SIGNATURE</b>
1. Inspect all liquid storage tanks, drums & containers for signs of corrosion and leakage. (Items stored outdoors)	<input type="checkbox"/>					
<b>NOTES:</b>						
2. Inspect all liquid storage tanks, drums & containers for supports, valves and fill ports ensuring properly capped, sealed and/or in good working order.	<input type="checkbox"/>					
<b>NOTES:</b>						
3. Inspect spill kits for proper placement and for containing adequate materials needed for spill response. Fill if needed.	<input type="checkbox"/>					
<b>NOTES:</b>						
4. Inspect the area to ensure that POLs stored outside are covered & contained (especially batteries) and are not stored in vicinity of storm drains or conveyance systems.	<input type="checkbox"/>					
<b>NOTES:</b>						
5. Inspect areas to ensure drip pans have been emptied, are not exposed to rain events and for condition (cracks, splits, holes or damage) replace if needed.	<input type="checkbox"/>					
<b>NOTES:</b>						
6. Inspect condition of marked storm drains (painted yellow or fish stencil).	<input type="checkbox"/>					
<b>NOTES:</b>						
7. Inspect ASTs Housekeeping pads for any POL sheen and remove any POLs, prior to release of any stormwater.	<input type="checkbox"/>					
<b>NOTES:</b>						
8. Inspect Oil Water Separators (if applicable), Oil & Grease Traps for heavy amounts of POLs in catch basin.	<input type="checkbox"/>					
<b>NOTES:</b>						
9. Inspect the area to insure all spills, regardless of quantity, are promptly handled according to Fort Stewart/HAAF Emergency Spill Response and Prevention Plan.	<input type="checkbox"/>					
<b>NOTES:</b>						